

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3774-0923:103

Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Securitron Magnalock, 550 Vista Blvd., Sparks, NV 89434
Contact: *Erik Strauss (775) 355-5625

DESIGN: Models XP-1 and XP-1F exit locking system. *System consists of the following subassemblies: BPS-12, -1, -3, -4.5, -6, -9, -15, BPS-24, -1, -2, -3, -4, -6, -10 power supplies, TSB-1, TSB-3, or XMS exit device (XP-1F requires 3100, 3300, 3600, 3700), Series 32, 34, 62 and 82 or SAM locking device, Models *TSH-BK and *TSH-CL Touch Sense Handle exit device, and LCP Lock Control Panel. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Input: 120 VAC, Output: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, NFPA 101 and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electric locking system. Model XP-1 is intended for installation on non-fire rated doors. Model X-1F is intended for installation on wood or metal fire rated doors. Authority having jurisdiction shall be consulted prior to installation.

NOTE: Both models may be used in conjunction with a separately listed fire alarm control panel, however, the units must be connected via the panels dry relay contacts designated a "Auxiliary". Connection to the fire alarm control unit "trouble" or "alarm relay" contacts is **NOT** approved.

*Rev. 12-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

DECEMBER 15, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager